

Lawton Adams Construction Corp.

260 Route 100
Somers NY 10589
Ph: 914-232-3275
Fax 914-232-4332

1 1/4 Washed Stone

<u>Sieve</u>	<u>Retained wgt.</u>	<u>%Retained</u>	<u>% Passing</u>	
2"	0.0	0.0	100.0	100
1 1/2"	60.4	8.8	91.2	90-100
1"	625.2	91.0	0.2	0-15
#200	1.1	0.2	0.0	0-1.0
Pan	<u>0.3</u>	<u>0.0</u>	*	
Total	687.0	100.0		