

8/1/2024

1/4 Washed Stone

<u>Sieve</u>	<u>Retained wgt.</u>	<u>%Retained</u>	<u>% Passing</u>	<u>Test 1A</u>
1/2"	0.0	0.0	100.0	100
1/4"	102.0	20.7	79.3	90-100
1/8"	385.9	78.5	0.8	0-15
#200	3.0	0.6	0.1	0-1.0
Pan	0.7	0.1	*	
Total	491.6	100.0		

Lawton Adams Construction Corp.

260 Route 100
Somers, NY 10589

Phone: 914-232-3275

Fax: 914-232-4332

9/11/2023

3/4 Washed Stone

<u>Sieve</u>	<u>Retained wgt.</u>	<u>%Retained</u>	<u>% Passing</u>	
1"	0.0	0.0	100.0	100
1/2"	1569.5	99.0	1.0	90-100
1/4"	9.0	0.6	0.4	0-15
#200	4.5	0.3	0.2	0-1.0
Pan	<u>2.5</u>	<u>0.2</u>	*	
Total	1585.5	100.0		

Lawton Adams Construction Corp

260 Route 100
Somers, New York 10589
Phone: 914-232-3275
Fax: 914-232-4332

9/11/2023

3/8 Washed Stone

<u>Sieve</u>	<u>Retained wgt.</u>	<u>%Retained</u>	<u>% Passing</u>	
1/2	0.0	0.0	100.0	100
3/8	15.0	14.0	86.0	80-100
#4	78.0	73.0	12.9	10 - 30
#8	7.2	6.7	6.2	0 - 10
#16	1.7	1.6	4.6	0 - 5
Pan	<u>4.9</u>	<u>4.6</u>	*	
Total	106.8	100.0		